

QUALITY ASSURANCE CERTIFICATION

DATE : 2021. 6. 29.

SAMWOO. CO., LTD
DEPARTMENT OF QUALITY CONTROL



PRODUCT NAME	ALUMINIUM SULFATE			
DATE OF ANALYSIS	2021. 6. 28.		INSPECTOR	Y.T. PARK <i>Y.T. Park</i>
TEST ITEMS	UNIT	SPECIFICATION	TEST RESULTS	REMARKS
Al ₂ O ₃	%	MIN 16.0	17.12	
pH	W/V%	MIN 3.0	3.30	
Fe	%	MAX 1.0	0.0013	
REMARKS : TESTED BY KS M 1411(ALUMINIUM SULFATE TEST METHOD)				
WE CERTIFY THE ABOVE STATEMENT OF QUALITY TO BE TRUE AND CORRECT.				